

OGDENSBURG CITY SCHOOL DISTRICT
OGDENSBURG, NEW YORK

SUBJECT: Annual School Fire Inspection Report

DATE: July 5, 2016

REASON FOR BOARD CONSIDERATION:

The Board of Education must be informed of the outcome of the District's Annual Fire Inspection.


FACTS AND ANALYSIS:

Since our District's fire inspection has been completed for all of our school facilities, the Board of Education must be informed regarding results of the inspection under Education Law 807-a. Mr. James McCarthy, Director of Facilities III, is present this evening to review the District's Annual Fire Inspection Report with the Board of Education.

RECOMMENDED ACTION:

Moved by _____ and supported by _____ that, having the approval of the Superintendent of Schools, the Board of Education of the Ogdensburg City School District does hereby accept the Annual Fire Inspection Report on the 5th day of July, 2016.

APPROVED FOR PRESENTATION TO THE BOARD:


Superintendent

TMV/alf
Attachment

NCE Services

April 6, 2016

Mr. Jim McCarthy
Superintendent of Buildings and Grounds
Ogdensburg City School District
1100 State St.
Ogdensburg, New York 13669

Re: 2016 Fire Inspections

Dear Mr. McCarthy:

I have completed the fire inspections of all the buildings in the district and the following violations were noted. It is required that these violations be corrected in order to receive a certificate of occupancy.

Garage 1

1. Item 12E1 Wire exposed where BX has pulled out of box on wall.

Garage 2- No violations noted.

Garage 3- No violations noted.

Garage 4- No violations noted.

Garage 5- No violations noted.

Garage 6- No violations noted.

36173 NYS Rt. 12E Clayton, New York 13624

315-654-5077

Central Receiving- No violations noted.

Track Shed- No violations noted.

Snack Barn- No violations noted.

Golden Dome

1. Item 17D2 Exit light west end not working

OFA

1. Item 10A2 Exit directions missing in 105, 114, 240, 302, 306, 307, 312, 313 & Band room.
2. Item 12J1 Improper use of an extension cord in 259. Surge to surge in room 267.

Kennedy School

1. Item 10A2 Exit directions missing in room 39 & 76 & Psychologist office.
2. Item 12E1 Appliances plugged into surge in rooms 36, 39, 108 & Faculty lounge.
3. Item 12J1 Surge to surge in room 93. Improper use of an extension cord in room 39.
4. Item 14D1 Rolling shutters not inspected in cafeteria.
5. Item 17D2 Exit sign missing in room 17.
6. Item 17H2 Emergency light not working in rooms 9 & 11.

Metal Storage Shed Kennedy- No violations noted.


Madill School

1. Item 12E1 GFCI required for aquarium in room 1. Appliance plugged into power strip in room 10.
2. Item 17H2 Emergency light not working in room 2, 18 & by rooms 12, 15 & 42.

Madill Storage Building - No violations noted.

Please advise me as to the date of the board meeting for the presentation of this report. You need to notify the public and the fire department as to the time and date of this meeting.

Sincerely yours,


John Warneck