

OGDENSBURG CITY SCHOOL DISTRICT
OGDENSBURG, NEW YORK

SUBJECT: Annual School Fire Inspection Report

DATE: July 5, 2017

REASON FOR BOARD CONSIDERATION:

The Board of Education must be informed of the outcome of the District's Annual Fire Inspection.

FACTS AND ANALYSIS:

Since our District's fire inspection has been completed for all of our school facilities, the Board of Education must be informed regarding results of the inspection under Education Law 807-a. Mr. James McCarthy, Director of Facilities III, is present this evening to review the District's Annual Fire Inspection Report with the Board of Education.

RECOMMENDED ACTION:

Moved by _____ and supported by _____ that, having the approval of the Superintendent of Schools, the Board of Education of the Ogdensburg City School District does hereby accept the Annual Fire Inspection Report on the 5th day of July, 2017.

APPROVED FOR PRESENTATION TO THE BOARD:


Superintendent

TMV/alf
Attachment

NCE Environmental Consultants

March 20, 2017

Mr. Jim McCarthy
Superintendent of Buildings and Grounds
Ogdensburg City School District
1100 State St.
Ogdensburg, New York 13669

Re: 2017 Fire Inspections

Dear Mr. McCarthy:

I have completed the fire inspections of all the buildings in the district and the following violations were noted. It is required that these violations be corrected in order to receive a certificate of occupancy.

Garage 1

1. Item 12E1 Wire exposed where BX has pulled out of box on the wall.
2. Item 12K1 Bad cord end on cord on bench.

Garage 2- No violations noted.

Garage 3- No violations noted.

Garage 4- No violations noted.

Garage 5- No violations noted.

Garage 6- No violations noted.

Central Receiving

1. Item 12G1 Panel box blocked.

**36173 NYS Rt. 12 Clayton, New York 13624
315-654-5077**

Track Shed- No violations noted.

Snack Barn- No violations noted.

Golden Dome

1. Item 17H2 Emergency light not working in tunnel.
2. Item 17L1 Exit light west end not working

OFA

1. Item 10A2 Exit directions missing in 100, 134, 218, 222, 223, 224, 225, 245, 246, 267, 305, 308 & 333.
2. Item 12E1 GFCI required for aquarium in room 134. Appliances plugged into surge in 221, 259 & 261.
3. Item 12I1 Multi-plug adaptor in Science room.
4. Item 12J1 Improper use of an extension cord in 113 & 267. Surge to surge in rooms 267, 320 & Band room.
5. Item 12K1 Missing cover plate in wood shop.
6. Item 17H2 Emergency lights not working by garbage room, by 119 & 114, Hallway by band room office, by 106B, middle school office, by elevator 1st. floor, by cafeteria (4), kitchen (3), 240, 301 & in 313 (2).

Kennedy School

1. Item 2E2 Blocked exit windows in rooms 7, 11, 13, 18, 21, 113 & 115.
2. Item 9D1 Materials stored within 2" of the ceiling in rooms 4, 9, 23, 39, 95, 105 & 106.
3. Item 10A2 Exit directions missing in rooms 10, 11 & 13.

4. Item 12E1 Appliances plugged into surge in rooms 36, 39 & Faculty lounge.
5. Item 14C2 Doors blocked open in rooms 4, 36 & 80.
6. Item 17H2 Emergency light not working in rooms 4, 5, 11 & 19.

Metal Storage Shed Kennedy- No violations noted.

Madill School


1. Item 12E1 Copier plugged into power strip in Faculty lounge. Bad cord end in room 12.
2. Item 12J1 Surge to surge in room 19.
3. Item 14C2 Door blocked open in rooms 2, 3, 4, 5, 9, 18, 19 & 21.
4. Item 17H2 Emergency light not working by electrical panel room near exit, nurse's office and kitchen.

Madill Storage Building - No violations noted.

General note: Could not find inspections stickers on sprinkler systems in two buildings or on the rolling shutters in the kitchens and some offices. These need to be in place.

Please advise me as to the date of the board meeting for the presentation of this report. You need to notify the public and the fire department as to the time and date of this meeting.

Sincerely yours,



John Warneck