

GENERAL ADMINISTRATION DIVISION
Report No. 1

OGDENSBURG CITY SCHOOL DISTRICT
OGDENSBURG, NEW YORK

SUBJECT: Annual School Fire Inspection Report

DATE: July 2, 2018

REASON FOR BOARD CONSIDERATION:

The Board of Education must be informed of the outcome of the District's Annual Fire Inspection.

FACTS AND ANALYSIS:

Since our District's fire inspection has been completed for all of our school facilities, the Board of Education must be informed regarding results of the inspection under Education Law 807-a. Mr. James McCarthy, Director of Facilities III, is present this evening to review the District's Annual Fire Inspection Report with the Board of Education.

RECOMMENDED ACTION:

Moved by _____ and supported by _____ that, having the approval of the Superintendent of Schools, the Board of Education of the Ogdensburg City School District does hereby accept the Annual Fire Inspection Report on the 2nd day of July 2018.

APPROVED FOR PRESENTATION TO THE BOARD:



Superintendent

TMV/alf
Attachment

NCE Environmental Consultants

February 4, 2018

Mr. Jim McCarthy
Superintendent of Buildings and Grounds
Ogdensburg City School District
1100 State St.
Ogdensburg, New York 13669

Re: 2018 Fire Inspections

Dear Mr. McCarthy:

I have completed the fire inspections of all the buildings in the district and the following violations were noted. It is required that these violations be corrected in order to receive a certificate of occupancy.

Garage 1 - No violations noted.

Garage 2- No violations noted.

Garage 3- No violations noted.

Garage 4- No violations noted.

Garage 5- No violations noted.

Garage 6- No violations noted.

Central Receiving

1. Item 17H2 Emergency light not working.

Concession Stand

1. Item 16B2 Fire extinguisher not inspected.

36173 NYS Rt. 12E Clayton, New York 13624
315.654.5077

Press Box - No violations noted.

Track Shed- No violations noted.

Snack Barn- No violations noted.

Golden Dome

1. Item 17H2 Emergency lights not working throughout.

OFA

1. Item 2E2 Exit directions missing throughout building.
2. Item 2D1 Rescue window not identified in wrestling room.
3. Item 12E1 Bad cord end in Cafeteria B.
4. Item 12J1 Improper use of an extension cord in Special Ed. Office & 241 (2).
5. Item 12K1 Broken plug in room 109.
6. Item 17H2 Emergency lights not working throughout the building.

Kennedy School

1. Item 10D1 Storage within 2' of the ceiling in room 18.
2. Item 17D1 Exit sign required on door in room 29 and the library.
3. Item 17H2 Emergency light not working in room 23.
4. Item 17L1 Exit light out in main gym.

Metal Storage Shed Kennedy- No violations noted.


Madill School

1. Item 15D2 Curtains on windows not treated for fire resistance in room 5.
2. Item 17H2 Emergency lights are not operating throughout the building.

Madill Storage Building – No violations noted.

Please advise me as to the date of the board meeting for the presentation of this report. You need to notify the public and the fire department as to the time and date of this meeting.

Sincerely yours,

A handwritten signature in black ink, appearing to read "John Warneck". The signature is fluid and cursive, with a large initial "J" and "W".

John Warneck