

NCE Environmental Consultants

January 16, 2019

Mr. Jim McCarthy
Director of Facilities III
Ogdensburg City School District
1100 State St.
Ogdensburg, New York 13669

Re: 2018 Fire Inspections

Dear Mr. McCarthy:

I have completed the fire inspections of all the buildings in the district and the following violations were noted. It is required that these violations be corrected in order to receive a certificate of occupancy.

Garage 1 – No violations noted.

Garage 2- No violations noted.

Garage 3- No violations noted.

Garage 4- No violations noted.

Garage 5- No violations noted.

Garage 6- No violations noted.

Central Receiving

1. Item 17H2 Emergency light not working.

Concession Stand – No violations noted.

Press Box – No violations noted.

Track Shed- No violations noted.

**36173 NYS Rt. 12E Clayton, New York 13624
315-654-5077**

Snack Barn- No violations noted.

Golden Dome

1. Item 17H2 Emergency lights not working throughout.

OFA

1. Item 2E2 Exit directions missing in rooms 268 & 335.
2. Item 3B1 Boiler Certification not found.
3. Item 12I1 Cover plate broken in metal shop.
4. Item 12J1 Improper use of an extension cord to surge in Special Ed. Office & 266.
5. Item 17H2 Emergency lights not working by 119, across from the woodshop, hallway outside of Cafeteria B (2).

Kennedy School

1. Item 17H2 Emergency light not working throughout.

Metal Storage Shed Kennedy- No violations noted.

Madill School

1. Item 17D2 Exit light in main gym not working.

Madill Storage Building – No violations noted.

Please advise me as to the date of the board meeting for the presentation of this report. You need to notify the public and the fire department as to the time and date of this meeting.

Sincerely yours,

John Warneck