

GENERAL ADMINISTRATION DIVISION  
Report No. 3

OGDENSBURG CITY SCHOOL DISTRICT  
OGDENSBURG, NEW YORK

---

SUBJECT: Annual School Fire Inspection Report

DATE: July 1, 2019

REASON FOR BOARD CONSIDERATION:

The Board of Education must be informed of the outcome of the District's Annual Fire Inspection.

FACTS AND ANALYSIS:

Since our District's fire inspection has been completed for all of our school facilities, the Board of Education must be informed regarding results of the inspection under Education Law 807-a. Mr. James McCarthy, Director of Facilities III, is present this evening to review the District's Annual Fire Inspection Report with the Board of Education.

RECOMMENDED ACTION:

Moved by \_\_\_\_\_ and supported by \_\_\_\_\_ that, having the approval of the Superintendent of Schools, the Board of Education of the Ogdensburg City School District does hereby accept the Annual Fire Inspection Report on the 1<sup>st</sup> day of July 2019.

APPROVED FOR PRESENTATION TO THE BOARD:

  
\_\_\_\_\_  
Superintendent

KK/alf  
Attachment

# **NCE Environmental Consultants**

January 16, 2019

Mr. Jim McCarthy  
Director of Facilities III  
Ogdensburg City School District  
1100 State St.  
Ogdensburg, New York 13669

Re: 2018 Fire Inspections

Dear Mr. McCarthy:

I have completed the fire inspections of all the buildings in the district and the following violations were noted. It is required that these violations be corrected in order to receive a certificate of occupancy.

**Garage 1 – No violations noted.**

**Garage 2- No violations noted.**

**Garage 3- No violations noted.**

**Garage 4- No violations noted.**

**Garage 5- No violations noted.**

**Garage 6- No violations noted.**

**Central Receiving**

1. Item 17H2            Emergency light not working.

**Concession Stand – No violations noted.**

**Press Box – No violations noted.**

**Track Shed- No violations noted.**

**36173 NYS Rt. 12E   Clayton, New York 13624  
315-654-5077**

**Snack Barn- No violations noted.**

**Golden Dome**

1. Item 17H2      Emergency lights not working throughout.

**OFA**

1. Item 2E2 Exit directions missing in rooms 268 & 335.
2. Item 3B1      Boiler Certification not found.
3. Item 12I1      Cover plate broken in metal shop.
4. Item 12J1      Improper use of an extension cord to surge in Special Ed. Office & 266.
5. Item 17H2      Emergency lights not working by 119, across from the woodshop, hallway outside of Cafeteria B (2).

**Kennedy School**

1. Item 17H2      Emergency light not working throughout.

**Metal Storage Shed Kennedy- No violations noted.**

**Madill School**

1. Item 17D2      Exit light in main gym not working.

**Madill Storage Building – No violations noted.**

Please advise me as to the date of the board meeting for the presentation of this report. You need to notify the public and the fire department as to the time and date of this meeting.

Sincerely yours,

John Warneck