

GENERAL ADMINISTRATION DIVISION

Report No. 1

OGDENSBURG CITY SCHOOL DISTRICT
OGDENSBURG, NEW YORK

SUBJECT: Annual School Fire Inspection Report

DATE: December 20, 2021

REASON FOR BOARD CONSIDERATION:

The Board of Education must be informed of the outcome of the District's Annual Fire Inspection.

FACTS AND ANALYSIS:

Since our District's fire inspection has been completed for all of our school facilities, the Board of Education must be informed regarding results of the inspection under Education Law 807-a. Mr. Christopher Kirwan, Director of Facilities III, is present this evening to review the District's Annual Fire Inspection Report with the Board of Education.

RECOMMENDED ACTION:

Moved by _____ and supported by _____ that, having the approval of the Superintendent of Schools, the Board of Education of the Ogdensburg City School District does hereby accept the Annual Fire Inspection Report on the 20th day of December 2021.

APPROVED FOR PRESENTATION TO THE BOARD:



Superintendent

KK/alf
Attachment

Ogdensburg City School District
1100 State Street, Ogdensburg, NY 13669
Christopher Kirwan
Director of Facilities III
315-393-0900 ext. 31927
email - ckirwan@ogdensburgk12.org



December 7, 2021

NCE Environmental Consultants
36173 NYS Rt. 12E
Clayton, NY 13624
315-654-5077

Attn: John Warnick

John,

Thank you once again for all the hard work you do for our facilities. We have addressed all concerns outlined in your 2021-2022 report with the exception of the emergency lights at Madill School. We are waiting for LED emergency lights to arrive (delayed in shipping), which we will install as soon as we receive them. Existing units requiring replacement batteries have been completed and are functioning properly.

I am writing to notify you that your report will be presented at the Ogdensburg City School Board meeting on December 20, 2021 at 6:00 p.m.

Thanks again for all you do. Wishing you and your family a wonderful Holiday!!

Sincerely

A handwritten signature in blue ink, which appears to read "Chris Kirwan". The signature is fluid and cursive, written over a light blue horizontal line.

Christopher Kirwan
Director of Facilities III/Transportation

Ogdensburg City School District
1100 State Street, Ogdensburg, NY 13669
Christopher Kirwan
Director of Facilities III
315-393-0900 ext. 31927
email - ckirwan@ogdensburgk12.org



December 3, 2021

Dear Mr. Kendall,

Enclosed please find a history of 2021 Fire Inspections as well as remedial actions taken to bring Ogdensburg City School facilities into compliance for your and the Boards review.

Find comfort in knowing our facilities are far better prepared going into the 2021-2022 school year with these remedial projects behind us.

With your permission I will forward a copy to Mr. John Warneck who has been an invaluable resource with any questions I had regarding the upgrades we undertook.

I'm available should you have any questions.

Sincerely,

A handwritten signature in blue ink that reads "Chris Kirwan".

Chris Kirwan

Director of Facilities III/Transportation