GENERAL A	DMINISTRATION	DIVISION
Report No.	1	

OGDENSBURG CITY SCHOOL DISTRICT OGDENSBURG, NEW YORK

SUBJECT:	Annual School Fire Inspection Report
DATE:	July 1, 2021
REASON FOR BOARD	CONSIDERATION:
	The Board of Education must be informed of the outcome of the District's Annual Fire Inspection.
FACTS AND ANALYSIS	:
	Since our District's fire inspection has been completed for all of our school facilities, the Board of Education must be informed regarding results of the inspection under Education Law 807-a.
RECOMMENDED ACT	ION:
	Moved by and supported by that, having the approval of the Superintendent of Schools, the Board of Education of the Ogdensburg City School District does hereby accept the Annual Fire Inspection Report on the 1 st day of July 2021.
APPROVED FOR PRES	ENTATION TO THE BOARD:
	Knikkeuh
	Superintendent

KK/alf Attachment

Ogdensburg City School District 1100 State Street, Ogdensburg, NY 13669

Christopher Kirwan
Director of Facilities III
315-393-0900 ext. 31927
email - ckirwan@ogdensburgk12.org



Dear Mr. Kendall,

Enclosed please find NCE Environmental Consultants November 22, 2020 Fire Inspection Report for all the buildings in the district.

Please note all deficiencies noted in the report have been addressed/corrected. As a result of Mr. Warneck's report a subsequent comprehensive inspection was ordered and performed by NCC Systems Inc. in December 2020 for all three schools pertaining to our kitchen facilities ansul, fire detection, fire notification and rolling door systems. Multiple deficiencies were found in all three schools and have been corrected or replaced with new code compliant systems. To date I believe we are in full compliance at all facilities.

The complete inspection and list of corrected items is extensive and available upon request.

I am available should there be any questions.

Sincerely,

Chris Kirwan

Director of Facilities III

NCE Environmental Consultants

November 22, 2020

Mr. Chris Kirwan Director of Facilities Ogdensburg City School District 1100 State St. Ogdensburg, New York 13669

Re: 2020 Fire Inspections

Dear Mr. Kirwan:

I have completed the fire inspections of all the buildings in the district and the following violations were noted. It is required that these violations be corrected in order to receive a certificate of occupancy.

Garage 1 – No violations noted.

Garage 2- No violations noted.

Garage 3- No violations noted.

Garage 4- No violations noted.

Garage 5- No violations noted.

Garage 6- No violations noted.

Central Receiving – No violations noted.

Concession Stand

1. Item 16B2 Fire extinguisher not inspected.

Press Box – No violations noted.

Track Shed - No violations noted.

Snack Barn - No violations noted.

Golden Dome

1. Item 17H2Emergency light not working in South Locker room, Hallway by Team rm. 4, in Team rm. 8 & Locker room 3.

OFA

- 1. Item 12E1 Appliances plugged into power strip in District Office.
- 2. Item 12I1 Multi-plug adaptor in 263.
- 3. Item 12K1 Cover plate missing in Faculty lounge room 108.
- 4. Item 13B2 Ansul system in kitchen not inspected.
- 5. Item 17H2 Emergency light not working in 114, 300, 301 and Nurse's office.

Kennedy School

- 1. Item 12E1 Appliances plugged into surge in rooms 42 & 43.
- 2. Item 13B2 Ansul system not inspected.
- 3. Item 14B2 Rolling doors in kitchen not inspected.
- 4. Item 16A2 Sprinkler system not inspected.
- 5. Item 17D2 Exit sign in both courtyards not working.

Metal Storage Shed Kennedy- No violations noted.

Madill School

1. Item 17H2Emergency light by intersection of Sturgeon and Bullhead not working..

Madill Storage Building

1. Item 16B2 Fire extinguisher missing.

Please advise me as to the date of the board meeting for the presentation of this report. You need to notify the public and the fire department as to the time and date of this meeting.

Sincerely yours,

John Warneck