

**Ogdensburg City School District**  
**1100 State Street, Ogdensburg, NY 13669**

*Brian Mitchell*

*Interim Director of Building/Grounds*

*Transportation/Cafeteria*

*315-393-0900 ext. 31927*

*email - [bmitchell@ogdensburgk12.org](mailto:bmitchell@ogdensburgk12.org)*



October 13, 2022

Dear Mr. Kendall,

All 2022 Fire Inspections have been completed and remedial actions were taken to bring Ogdensburg City School facilities into compliance.

I'm available should you have any questions.

Sincerely,

Brian Mitchell

# **NCE Environmental Consultants**

September 16, 2022

Mr. Brian Mitchell  
Director of Facilities  
Ogdensburg City School District  
1100 State St.  
Ogdensburg, New York 13669

Re: 2022 Fire Inspections

Dear Mr. Mitchell:

I have completed the fire inspections of all the buildings in the district and the following violations were noted. It is required that these violations be corrected in order to receive a certificate of occupancy.

**Garage 1**– No violations noted.

**Garage 2** - No violations noted.

**Garage 3** - No violations noted.

**Garage 4** - No violations noted.

**Garage 5** - No violations noted.

**Garage 6** - No violations noted.

**Central Receiving**

1. Item 17H2      Emergency light not working - back

**Concession Stand**

1. Item 17H2      Emergency light not working in storage area.

**Press Box** – No violations noted.

**Track Shed** - No violations noted.

**Snack Barn** - No violations noted.

**36173 NYS Rt. 12E   Clayton, New York 13624  
315-654-5077**

**Golden Dome**

1. Item 17D2 Exit light not working in girls team rm. 9.
2. Item 17H2 Emergency lights not working in boys locker room-tunnel, mechanical room, concession stand & girls team room 9.

**OFA**

1. Item 10A2 Exit directions missing in 102, 116, 318B, 341 and earth science lab.
2. Item 12E1 Appliances plugged into power strips in library, guidance breakroom, 246, 346 & 349.
3. Item 12K1 Exposed wire in pool pump room.
4. Item 16B2 Fire extinguisher missing in room 321.
5. Item 17D2 Exit light in courtyard not working.
6. Item 17H2 Emergency light not working by 103, 120 (2), 122, 248, 303, 306, 312, 318, library and LGI. & academy street custodial 1<sup>st</sup>. floor.

**Kennedy School**

1. Item 3B1 Boiler inspection missing.
2. Item 10A2 Exit directions missing in 9, 16, 34, 43, 54 & 65.
3. Item 12E1 Appliances plugged into power strip in 1, 42 & 55.
4. Item 12G1 Electrical panels blocked in Data room by room 29 & electrical room by room 46.
5. Item 15A2 Paper covering door window in 43, 61 & 64.
6. Item 15D2 Tape covering light in 43.

**Metal Storage Shed Kennedy**

1. Item 17D2 Exit sign missing.

**Madill School**

1. Item 2E2 Rescue window blocked in 1.
2. Item 10A2 Exit directions missing in Adaptive gym.
3. Item 15A2 Window door lite covered in 5, resource room and across from 14.

4. Item 17H2      Emergency lights not working outside library, cafeteria, room 12 & by girl's locker room (2).

**Madill Storage Building** -No violations noted

Please advise me as to the date of the board meeting for the presentation of this report. You need to notify the public and the fire department as to the time and date of this meeting.

Sincerely yours,

John Warneck