

# **NCE Environmental Consultants**

October 21, 2021

Mr. Chris Kirwan  
Director of Facilities  
Ogdensburg City School District  
1100 State St.  
Ogdensburg, New York 13669

Re: 2021 Fire Inspections

Dear Mr. Kirwan:

I have completed the fire inspections of all the buildings in the district and the following violations were noted. It is required that these violations be corrected in order to receive a certificate of occupancy.

**Garage 1**– No violations noted.

**Garage 2** - No violations noted.

**Garage 3** - No violations noted.

**Garage 4** - No violations noted.

**Garage 5** - No violations noted.

**Garage 6** - No violations noted.

**Central Receiving** – No violations noted.

**Concession Stand**

1. Item 17H2 Emergency light not working.

**Press Box** – No violations noted.

**36173 NYS Rt. 12E Clayton, New York 13624  
315-654-5077**

**Track Shed** - No violations noted.

**Snack Barn** - No violations noted.

**Golden Dome** – No violations noted.

**OFA**

1. Item 2D1                Rescue window sticker missing in 219, 246 & 305.
2. Item 10A2            Exit directions missing in 115, 134, 137, 214, 243, 244, 247, 250, 258, 260, 268, 300, 335, 340, 355 & District Office.
3. Item 12J1            Appliances plugged into power strips in CSE Kitchen, 117A, Lab storage (119), 313 & 306.
4. Item 15D2            Lights covered with blue fabric in 318A & 318B.
5. Item 17H2            Emergency light not working in pool bathroom, small gym (2), Dome tunnel & 304.
6. Item 17L1            Exit light not working in 105, Courtyard (2), and by elevator boiler room.

**Kennedy School**

1. Item 2E2                Exit window blocked in 38 & 155.
2. Item 10A2            Exit directions missing in 14, courtyard door in 29, 38, 41, 43, 46, library and computer lab.
3. Item 12E1            Appliances plugged into power strip in 6, 24, 26 & 47 and Fridge plugged into extension cord in Maintenance office.
4. Item 12G1            Electrical panels blocked in Data room by room 29 & electrical room by room 46.
5. Item 15D2            Lights covered by blue fabric in 43.
6. Item 17H2            Emergency light not working in 29 & 66.

**Metal Storage Shed Kennedy**

1. Item 16A2 Fire extinguisher not inspected.

**Madill School**

1. Item 10A2 Exit directions missing in 22, 25 & 30.
2. Item 17H2 Emergency lights not working in numerous locations throughout the building.

**Madill Storage Building** -No violations noted

Please advise me as to the date of the board meeting for the presentation of this report. You need to notify the public and the fire department as to the time and date of this meeting.

Sincerely yours,

John Warneck